



MATERIALS TESTING, INC.

55 LAURA STREET, NEW HAVEN, CT 06512 - (203) 468-5216
42 BOSTON POST ROAD, WILLIMANTIC, CT 06226 - (860) 423-1972
www.materialstestinginc.com

CLIENT: McClure Construction Co.
PO Box 367
Waterford, CT 06385

DATE: April 28, 2016

REPORT # M-1092

PROJECT: Client's Information

SUBJECT: Modified Proctor Analysis, ASTM D-1557-A


MATERIAL: Fine Silt

SOURCE: McClure Pit

SAMPLED BY: client and delivered to MTI

RECEIVED: April 24, 2016

MAXIMUM DRY DENSITY: 118.9 PCF @ 13.9% 0% Plus #4



lcc: Client
lcc: J McClure

wlb



Materials Testing, Inc.

William J. Soucy