



# MATERIALS TESTING, INC.

55 LAURA STREET, NEW HAVEN, CT 06512 - (203) 468-5216  
42 BOSTON POST ROAD, WILLIMANTIC, CT 06226 - (860) 423-1972  
www.materialstestinginc.com

**CLIENT:** McClure Construction Co.  
PO Box 367  
Waterford, CT 06385

**DATE:** April 22, 2016

**REPORT #** M-1090

**PROJECT:** Client's Information

**SUBJECT:** Modified Proctor Analysis, ASTM D-1557-A


**MATERIAL:** Fine Silt

**SOURCE:** McClure Pit

**SAMPLED BY:** client and delivered to MTI

**RECEIVED:** April 15, 2016

**MAXIMUM DRY DENSITY:** 106.7 PCF @ 15.1% 0% Plus #4



lcc: Client  
lcc: J McClure

wlb

Materials Testing, Inc.

William J. Soucy